



## 2nd Floor

| MTL # | MATERIAL DESCRIPTION            | LOCATION   | F/NF <sup>1</sup> | COND. <sup>2</sup> | % ACM                         | # SAMP. | QUANTITY  |
|-------|---------------------------------|--|-------------------|--------------------|-------------------------------|---------|-----------|
| 25    | White spray-on ceiling material | 2078, 2064, 2032, 2002                               | F                 | Good               | 4%                            | 9       | 11,400 SF |
| 26    | Blue carpet mastic              | 2078   | NF                | Good               | ND                            | 3       | N/A       |
| 27    | Black cove base/mastic          | All rooms except 2106, 2070, 2042a, 2036, 2014, 2108 | NF                | Good               | Cove base = ND<br>Mastic = ND | 3       | N/A       |



