

**California State University East Bay**  
**Testing for Lead Levels in Drinking Water and Follow up Actions**  
(updated on 07/11/2018)

Phase 1 water samples from university drinking water sources were collected during the month of June by Intertek PSI Environmental Services and sent to a California certified laboratory for analysis. Test results are presented in the following table. The action level is set at the EPA's Maximum Contaminant Level (MCL) of 15 ppb (1 ug/liter = 1 ppb or part per billion). A&E 1

	st Fl.	Water fountain by MRR 161	< 5	No action required
5	A&E 2 <sup>nd</sup> Fl.	Water fountain by Rm. 260E	< 5	No action required
6	A&E 3 <sup>rd</sup> Fl.	Water fountain by Rm. 360	< 5	No action required
7	A&E 3 <sup>rd</sup> Fl.	Sink faucet in Breakroom Rm. 392	10	No action required
8	A&E 1 <sup>st</sup> Fl.	Sink faucet in Breakroom Rm. 193	9	No action required
122	A&E 1 <sup>st</sup> Fl.	Water fountain (R) near Rms. 142/153	5	No action required
123	A&E 1 <sup>st</sup> Fl.	Water fountain (L) near Rms. 142/153	< 5	No action required
124	A&E 1 <sup>st</sup> Fl.	Sink faucet (1) in Lab 153	9	No action required

Sample Number	Building and Floor	Sample Location	Lead Conc. (ppb)	Action
---------------	--------------------	-----------------	------------------	--------

22	MI 2 <sup>nd</sup> Fl.			
----	------------------------	--	--	--

Sample Number	Building and Floor	Sample Location	Lead Conc. (ppb)	Action
54B	KPE 2 <sup>nd</sup> Fl.	Water fountain in Gym Rm. 202	< 5	No action required
55	KPE 2 <sup>nd</sup> Fl.	Water fountain in Rm. 201A (R)	12	No action required
56	KPE 2 <sup>nd</sup> Fl.	Water fountain in Rm. 201A (L)	7	No action required
57	KPE 1 <sup>st</sup> Fl.	Sink		

Sample Number	Building and Floor	Sample Location	Lead Conc. (ppb)	Action
				<i>service</i>
84	Science 2 <sup>nd</sup> Fl.	Water fountain near Rm. S204	< 5	No action required
85	Science 2 <sup>nd</sup> Fl.	Water fountain near Rm. S204	< 5	No action required
<b>86</b>	<b>Science 2<sup>nd</sup> Fl.</b>	<b>Water fountain near Rm. S247</b>	<b>16</b>	<b>Removed</b>

Sample  
Number

Building and

707Tc18orjTT31Tf2.990984TD0Tc<0003TET/Cs6cs.93333.92549.88235scn122976679.2761.3640.32ref12